



Worcester County Administration Office
1 West Market Street, Room 1103
Snow Hill, MD 21863
Ph. 410-632-1194 Fax 410-632-3131
Email: purchasing@co.worcester.md.us

Addendum # 1 – Blacktop Resurfacing at Recreation Center

March 10, 2026

Date of Addendum:

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – ATTACHMENTS

Item	Description
1	Aerial view of Recreation Center

2.0 – CLARIFICATIONS

The following clarifications are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Description
------	-------------

3.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
	<ol style="list-style-type: none">1. Please provide a sketch or aerial image showing the surface area/s to be paved at each location. Aerial views are attached. Please note these are approximate and field measuring is suggested.2. Do the complete area/s to be paved require 2” milling or just taper milling and butt joints? A minimum of 6 feet of tapered milling is required in all areas the pavement meets with concrete, doorways, walkways or existing pavement. Butt-joints to existing asphalt aren't acceptable. A keyed joint is preferred.3. Will the County take any millings generated from these projects? If so, where do you want the millings delivered? Yes, the County will take all millings. Deliver to our Roads Facility, 5764 Worcester Hwy, Snow Hill.

	<ol style="list-style-type: none">4. The specifications indicate hot mix will be measured and paid by the ton. However, the bid form does not have any bid items only a space for the total fixed price. Are bid form pages missing? Lump sum pricing is sufficient.5. Is waterborne paint suitable for the pavement markings? A water-based acrylic traffic paint is sufficient.6. It is understood that a performance/payment bond is required for contracts over \$100,000. Is a bid bond required for either of these bids? A bid bond isn't required for these projects.
--	--

END OF ADDENDUM