



Worcester County Administration Office
1 West Market Street, Room 1103
Snow Hill, MD 21863
Ph. 410-632-1194 Fax 410-632-3131
Email: purchasing@co.worcester.md.us

Addendum # 1 - Dugout Replacement Project at John Walter Smith Park (Question & Answer)

Date of Addendum: **July 2, 2026**

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – ATTACHMENTS

Item	Description

2.0 – CLARIFICATIONS

The following clarifications are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Description

3.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1	Are there any gates required for the dugouts, or just an opening, and what size would that be? No gates are required for the dugouts. Gates already exist on each baseball/softball field. The opening on the dugout will be approximately 10' wide.

END OF ADDENDUM