



Worcester County Administration Office
1 West Market Street, Room 1103
Snow Hill, MD 21863
Ph. 410-632-1194

Addendum # 2 – RFP 27-WWW-01 River Run to PS C PER (Additional Q&As)

Date of Addendum: **August 20, 2026**

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – ATTACHMENTS

Item	Description
-------------	--------------------

2.0 – CLARIFICATIONS

The following clarifications are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Description
-------------	--------------------

3.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1	Can the County provide information on the scope of the planned improvements at the River Run WWTP facility? The planned improvements at the River Run WWTP are not included in the scope of this project. The purpose of this project is to evaluate options that would provide the County with short- and long-term operational flexibility for diverting wastewater flows from the River Run WWTP should rehabilitation, upgrades, or other improvements be needed in the future. The PER will evaluate temporary, semi-permanent, and permanent diversion alternatives and their potential impacts on PS-C and the Ocean Pines WWTP. The specific scope and design of future improvements at the River Run WWTP will be developed separately.
2	Can the County please provide information on the capacity and configuration of Pump Station C? See Section IV.C.1 of the RFP. Document requests will be provided after award.
3	Paragraph G. ACCEPTANCE OR REJECTION OF PROPOSALS Number 5. makes reference to a “required Bid Security.” As Design Professionals, Bid Security is typically not required or attainable. Please verify that no Bid Security is required for this Proposal Submittal. No bid security required.
4	Are GIS contours sufficient for development of the topographic surface for Task 2 of the PER? GIS contours meeting QL1 or QL 2 quality standards will be accepted for the development of the topographic surface, provided it is supplemented with targeted field surveys. Physical field verification will be required for utility locates, critical system tie-ins, and utility invert elevations. Additionally, field survey shots will be required to spot cross-check the GIS dataset accuracy and to map terrain in areas where dense tree cover limits remote-sensing accuracy.

END OF ADDENDUM

