



Worcester County Administration Office
1 West Market Street, Room 1103
Snow Hill, MD 21863
Ph. 410-632-1194

Addendum # 3 – Parking Project at John Walter Smith (JWS) Park (Additional Questions & Answers)

Date of Addendum: August 7, 2026

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – ATTACHMENTS

Item	Description

2.0 – CLARIFICATIONS

The following clarifications are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Description

3.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1	Is a bid bond required? The County doesn't require a Bid Bond for this project but does require both Payment & Performance Bonds as shown on pages 14 & 15 of the bid documents.
2	Is there any payment retainage? Retainage is not required due to the contractor supplying both Performance & Payment Bonds.
3	On plan sheet C-9.1, the striping detail shows 5" Thermo solid white stripes and also 4" solid white paint stripes. Please clarify the size and material for the parking lot stripes. 4" Wide Thermoplastic for the striping.

END OF ADDENDUM